

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHER/K-I/179

Dated: 14-06-24

It is certified that an inspection team headed by Pradeep Singh Jamwal

(Name of Officers with designation) from PHE Rural Div. Jammu PHED

inspected the SGSD International School, Domana Jammu

(Name & Address of the school) on 11/6/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PHE SDI/Lab.-419 dated 14-06-24

of D.W.T.L, Sit lee Jammu (PHED Lab) certified that the

SGSD International School (Name of school) has safe drinking water

Domana, Jammu

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt. (Exclusively for Safe Drinking Water and Sanitary Condition)

This certificate is valid till 14-06-25

Signature with Seal: Assistant Executive Engineer
Name: PHE Rural Sub Division
Designation: Sandeep Kumar
Name & Address of the Office / Department: A.E.E.

To SGSD International School, Domana, Jammu PHE Rural Div. Reasi Sub.Div. Kandl-I
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



DISTRICT WATER TESTING LABORATORY, SITLEE, JAMMU
JAL SHAKTI (PHE) DEPARTMENT, JAMMU, UT OF J&K
DOC Ref: PHE/WQC/DSL/QF-7.8-01



TC-13033

TEST REPORT

Client Name:	S.G.S.D International School, Machine Domana		
Client Ref No:	SGSD/2024-25/230		
Sample Quantity:	1 liter	Sample Container Condition:	OK / Not Satisfactory
Sample ID:	PHE DLS/TR-245	Date of Receipt:	13-6-24
Report No:	PHE SDI/lab.-419	Report Date:	14-6-24
Sample Details:	Machine Domana	Source:	Tap Water
Test Start Date:	13-6-2024	Test End Date:	14-6-24
Sample Collected by	Sample collected and Provided by Consumer		

Sr. No.	Parameter	BIS Permissible Limit	Unit	Test Results Temp. @ 25 ± 2, Humidity (40-60)%	Test Method
1.	pH	6.5-8.5	--	7.65	IS 3025 (Part 11)
2.	Colour	15	HU	5	IS 3025 (Part 4)
3.	TDS	2000	mg/l	538	IS 3025 (Part 16)
4.	Turbidity	5	NTU	1.16	IS 3025 (Part 10)
5.	Iron	1.0	mg/l	0.18	IS 3025 (Part 53)
6.	Chloride	1000	mg/l	42.23	IS 3025 (Part 32)
7.	Magnesium	100	mg/l	22.35	IS 3025 (Part 46)
8.	Sulphate	400	mg/l	30.8	IS 3025 (Part 24)
9.	Calcium	200	mg/l	96.99	IS 3025 (Part 40)
10.	Total Hardness	600	mg/l	334	IS 3025 (Part 21)
11.	Alkalinity	600	mg/l	187.5	IS 3025 (Part 23)

Note:

- The test report and result relate to the material's specimen/ sample (s) as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test report.
- WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/ legal liability arising out of any errors or omissions.
- The report has been presented in a simplified manner and the test conditions will be available on request.
- This laboratory does not provide the statement of conformity (Pass/ Fail), opinion and interpretation.
- Results apply to the sample as received.

*ADL: Above Detectable Limits, *BDL: Below Detectable Limits

Reviewed by:

(Mr: Vinod Kumar) (Chemist)
Designation:
(Chemist)

Authorised Signatory

(Mr:)
Designation: (JE)

End of Report